

## ADDENDUM #1

### Tender No. ENG 26-03 – TOE Esquimalt Rd Phase 2 – Active Transportation and Underground Utility Renewals

Please note the following Clarifications, Questions and Answers for the above noted Tender is to be known as Addendum #1. Bidders are to reference receipt of Addendum #1 in their submission.

#### Clarification:

All **tender submissions and inquiries** are to be directed to both of the following contacts:

- Pearl Barnard – *pearl.barnard@esquimalt.ca*
- Charles Davie – *charles.davie@esquimalt.ca*

#### Bidder Questions and Township Answers:

**Question #1:** Can a two-week extension be provided.

**Answer#1:** No Extensions will be provided as we are targeting tender award recommendation to council before their summer break.

**Question #2:** Please clarify the intent of the Type 1 and “flush nose” concrete median details shown on Sheets 7, 9 and 10, including applicable dimensions, lengths, and whether the medians are intended to be precast installations.

**Answer#2** The intention of both the “flush nose” concrete crossing median and the Type 1 concrete median is for these elements to be cast-in-place concrete installations, not precast.

Please refer to the applicable details on Sheet 10 for median dimensions and installation details.

Median lengths, widths, and locations are as shown on the contract drawings and reflected in the Schedule of Quantities. Final installation locations are to be confirmed in the field with the Contract Administrator prior to installation.