

ADDENDUM #3

Tender No. ENG 25-02 – Esquimalt Rd Phase 1 – Active Transportation and Underground Improvements / Craigflower Rd Crosswalk Upgrades

Please note the following Clarifications, Questions and Answers for the above noted Tender is to be known as Addendum #3. Bidders are to reference receipt of Addendum #3 in their submission.

All **tender submissions and inquiries** are to be directed to both of the following contacts:

- Pearl Barnard – pearl.barnard@esquimalt.ca
- Charles Davie – charles.davie@esquimalt.ca

1. **Bidder Questions and Township Answers:**

Question #1: Within the Traffic Signals work for Esquimalt Road, there is optional work shown on E06, but the SoQ doesn't mention any optional work in item 6.5. Not sure if we should include for this or not...

Answer #1: All work shown on drawing E06 is to be included in the bid, is not optional, and must be priced under item 6.5.

Question #2: Some BCH poles have a luminaire to be swapped out for a new one. Is the Owner or the Contractor paying for utility company to do this work?

Answer #2: Contractor