

ADDENDUM #2

Invitation to Bid – Esquimalt Recreation Centre Pool Dehumidifier Project

RFI

- Please indicate the thickness of rigid board insulation for the exterior duct insulation. Flexible insulation is not suited for aluminum jacketing.

Rigid or blanket type thermal insulation on ductwork located outdoors shall be 50mm thick